

LC-103-PIMSK (Form A)**LC-123-PIMSK (Form C)**

Dual-Tech Motion Sensor (PIR & Microwave) with Pet

Immunity & Anti-Mask

Sensor de movimiento de tecnología doble (sensor PIR y microondas) con inmunidad a mascotas y función de anti-enmascaramiento

DéTECTeur de mouvement bi-technologie (IPR & hyperfréquence) avec immunité aux animaux domestiques et protection antimasque

Rilevatore di Movimento a Doppia Tecnologia (Infrarosso + Microonda)


con immunità agli animali e antimascheramento
Dualna czujka ruchu (pasywna podczerwień i mikrofalowa)
odporno na obecność zwierząt z „antymaskingiem”

Fig. 1 Knockout holes | Orificios troquelados | Trou de débouchure I Fori ciechi | Otwory montażowe


LC-1L1ST accessory bracket Installation - Wall mount bracket (ceiling mount available)

Instalación del soporte-Escuadra de montaje en pared (escuadra para techo disponible)

Installation du support-Support de montage mural (support pour montage au plafond disponible)

Instalazione dello snodo-Snodo per il montaggio a parete (disponibile snodo per il montaggio a soffitto)

Montaż uchwytu- Uchwyt do montażu na scianie (dostępny także uchwyt do montażu na suficie)

Fig. 2 Detector Installation
Instalación del detector
Installation du détecteur
Installazione del rilevatore
Montaż czujki

ENGLISH

The detector provides an analysis of environmental conditions through the entire movement speed frequency spectrum, allowing focus on intruders and eliminating environmental factors of false alarms. The spectrum analysis is embedded in the VLSI based electronics of the detector assuring high reliability and trouble free operation. Unique function-anti-mask-guarantees detector protection from non desirable approach and any kind of masking beginning from the distance 0.8m and closer.

As the LC-103-PIMSK / LC-123-PIMSK is a combined technology (PIR & microwave) an alarm signal relay activation occurs only when signals from both sensors (PIR & MW) are present at the same time. The effective detection range is the range of which the patterns (PIR & MW) are intersected. The GAIN potentiometer adjustment changes the MW signal intensity so that the effective pattern will be scaled. This Installation Manual shall be used in conjunction with the Installation Manual of the Control Panel.

TYPICAL INSTALLATION

Select mounting location

Choose a location most likely to intercept an intruder. (Our recommendation is a corner installation). See detection pattern (Fig.3). The quad-element high quality sensor detects motion crossing the beam; it is slightly less sensitive detecting motion toward the detector.

Avoid The Following Locations: * Facing direct sunlight. * Facing areas that may change temperature rapidly. * Areas where there are air ducts or substantial airflows. The LC-103-PIMSK / LC-123-PIMSK perform better when provided with a constant and stable environment.

This detector shall be installed and used within an environment that provides the pollution degree max 2 and overvoltages category II, NON HAZARDOUS LOCATIONS, indoor only. The detector is designed to be installed by service persons only.

NOTE: The anti-mask detection output will open for a minimum of 30 seconds and will close only if a signal is received from the PIR after the initial 30 second period.

MOUNTING THE DETECTOR

1. Remove the front cover by unscrewing the holding screw (Fig. 2-11) and gently raise the front cover. (Fig. 2-5)
2. Remove the PC board by unscrewing the holding screw located on the board. (Fig. 2-9)

3. Break out the desired holes for proper installation (Fig. 1 – 2) for flat mount or Fig. 1-3 for corner mount) Use 4 screws type 3x30mm.

4. The circular and rectangular indentations at the bottom base (Fig. 1-1, Fig. 1-4) are the knockout holes for wire entry.

5. Mount the detector base to the wall or corner.

6. For optional LC-1L1ST accessory bracket installation open hole Fig. 1-6 for the bracket screw and install Bracket wall adapter (Fig. 2-1&3) or Bracket ceiling adapter (Fig. 2-2&3)

7. Reinstall the PC board by fully tightening the holding screw.

8. Connect wire to terminal block.(Fig. 4)

9. Replace the cover by inserting it back in the appropriate closing pins and screw with the holding screw.

If back tamper is assembled (Fig.1-6) there is no bracket option and the detector must be installed in flat mounting only

DETECTOR INSTALLATION

Terminal Block Connections (See Fig. 4)

Terminals 1 & 2 - Marked "T1, T2" (TAMPER) Connect these terminals to a 24-hour normally closed protective zone in the control unit. If the front cover of the detector is opened, an immediate alarm signal will be sent to the control unit.

Terminals 3 & 4 - Marked "AM: NC, C" This is the alarm output relay of Anti-Mask detection.

Terminal 5 Marked "NC" - This is the NC (Normally Closed) output of ALARM relay. (This contact is functional on LC-103-PIMSK and LC-123-PIMSK)

Terminal 6 Marked "C" - This is the COMMON output of ALARM relay. (This contact is functional on LC-103-PIMSK and LC-123-PIMSK)

Terminal 8 - Marked "-" (GND) Connect to the negative Voltage output or ground of the control panel.

Terminal 9 - Marked "+" (+12V) Connect to a positive Voltage output of 9.6-16VDC source. Use only a listed power limited source.

Note: The detector shall be provided with minimum of 4 hours of standby power from either a listed compatible control unit or power supply.

SETTING - UP THE DETECTOR (Dipswitch Fig.5-2)

LED ENABLE / DISABLE

Switch 1. Used for Setting "LED"

Position Up "ON" - LED ENABLE The RED LED will activate when the detector is in alarm condition. (Factory Settings)

Position Down "OFF" - LED DISABLE The LED's are disabled.

NOTE: The state of the switch "LED" - does not affect the operation of the relay. When an intrusion is detected, the alarm relay will switch into alarm condition for 2 sec. In Al arm condition all 3 LED's blink together regardless of the LED switch position.

ANTI MASK FUNCTION

Switch 2. Used for Setting "AM" - Anti Mask function

Position Up "ON" - protection against masking the detector from 0.4m and closer. (Factory Settings)

Position Down "OFF" - protection against masking the detector from 0.8m and closer.

PIR SENSITIVITY ADJUSTMENT

Switch 3. Used for Setting "PIR" - provides sensitivity control of PIR according to the environment.

Position Up "ON" - (Pulse=1) - High sensitivity for stable environments. (Factory Setting)

Position Down "OFF" Position - (Pulse=Auto) - Low sensitivity for harsh environments. For ULC installations use this position

PET IMMUNITY SETTING

Switch 4. Used for Settings "PET" 15kg-25kg(33lbs-55lbs)

Position Up "ON" - Immunity to an animal up to 15 kg (33lbs)

Position Down "OFF" - Immunity to an animal up to 25 kg (55lbs) (Factory Settings)

Note: Pet immunity feature has not been tested by UL.

NOTE: Detector must be restart by temporary remove power before the new settings will take effect.

RANGE CALIBRATION (Fig. 5.1 and 5.4) The "MW" potentiometer adjusts the detection Range of MW between Minimum and Maximum (factory set to Middle Position).

The "PIR" potentiometer adjusts the detection Range between Minimum and Maximum (factory set to Middle Position).

NOTE: The "MW" and "PIR" potentiometer may need to be adjusted to the Maximum positions in order to achieve maximum area of coverage as indicated in Fig. 3.

WIRE SIZE REQUIREMENTS

Use #22 AWG (0.5 mm) or wires with a larger diameter. Use the following table to determine required wire gauge (diameter) and length of wire between the detector and the control panel.

ESPAÑOL

Este detector proporciona un análisis de las condiciones ambientales a lo largo del espectro completo de velocidades de movimiento, lo que le permite centrarse en intrusos y eliminar los factores ambientales típicos de las falsas alarmas. El análisis del espectro está integrado en la electrónica del detector basada en la tecnología VLSI, lo que asegura una alta fiabilidad y un funcionamiento libre de problemas. Unique function-anti-mask-guarantees detector protection from non desirable approach and any kind of masking beginning from the distance 0.8m and closer.

As the LC-103-PIMSK / LC-123-PIMSK is a combined technology (PIR & microwave) an alarm signal relay activation occurs only when signals from both sensors (PIR & MW) are present at the same time. The effective detection range is the range of which the patterns (PIR & MW) are intersected. The GAIN potentiometer adjustment changes the MW signal intensity so that the effective pattern will be scaled. This Installation Manual shall be used in conjunction with the Installation Manual of the Control Panel.

Este Manual de instalación deberá utilizarse conjuntamente con el Manual de instalación del panel de control de la alarma.

INSTALACIÓN TÍPICA

Selección de la ubicación de montaje

Elegir una ubicación en la que estime más probable la intercepción de un intruso. (Nuestra recomendación es la instalación en una esquina). Véase el patrón de detección (Fig. 3). El sensor Quad de alta calidad detecta todo movimiento que cruza el haz, y es algo menos sensible en la detección del movimiento hacia el propio detector.

Evite los siguientes emplazamientos : * Exposición a la luz directa del sol. * Exposición a zonas en las que la temperatura pueda variar rápidamente. * Zonas en las que existan conductos de aire o corrientes de aire importantes. *El LC-103-PIMSK / LC-123-PIMSK presenta un comportamiento óptimo en un entorno constante y estable.*

Este detector deberá instalarse y utilizarse en un entorno que proporcione como máximo el grado de contaminación 2 y la categoría de sobretensión II, UBICACIONES NO PELIGROSAS, y sólo en interiores. El detector está diseñado para su instalación únicamente por parte de personal de servicio técnico.

REMARQUE: Le 103PMSK déclenche un signal d'alarme antimasking uniquement après avoir reçu un signal du détecteur IPR mais pas moins de 30 sec. après l'activation de l'alarme antimasking.

MONTAGE DU DÉTECTEUR

1. Enlevez le couvercle en dévissant la vis (Fig 2-11) et soulevez doucement le couvercle. (Fig 2-5)
2. Enlevez la carte en dévissant la vis qui l'affix. (Fig 2-9)

3. Ouvrez les trous désirés pour l'installation (Fig 1-2) pour le support plat ou (Fig 1-3) pour le support d'angle. Employez 4 vis de type 3x30mm.

4. Les impressions circulaires et rectangulaires sur la base (Fig 1-1, Fig 1-4) sont les trous pour l'entrée de fil.

5. Montez la base du détecteur au mur ou au coin

6. Pour l'installation optionnelle avec la base ouvrez le trou (Fig 1-6) pour la base et installez l'adaptateur pour le mur. (Fig 2-1&3) ou l'adaptateur pour le plafond (Fig 2-2&3)

7. Reinstallez la carte en serrant la vis.

8. Reliez le fil au bloc terminal. (Fig 4)

9. Remplacez la couverture en l'insérant en arrière dans les goupilles appropriées de fermeture et attachez la vis.

10. Si la surveillance arrière est assemblée (Fig.1-6) il n'y a aucune option de montage. Le détecteur doit être installé plat seulement.

INSTALLATION DU DÉTECTEUR

Connexions de la plaque à bornes (Voir Fig.4).

Bornes 1 & 2 - Signalées par "T1,T2" (TAMPER?) Reliez ces bornes à une zone de protection normalmente cerrada de 24 horas sobre el unidad de control. Si el cubreteo del detector esté abierto, un señal de alarma será inmediatamente enviado al paneón de control.

Bornes 3 & 4 - Signaladas por "AM : NC, C" C'est le relais de sortie d'alarme de la détection antimasking.

Borne 5 marqué "NC" - c'est le rendement normalmente fermé du relais d'ALARME. (Ce contact est fonctionnel sur LC-103-PIMSK et LC-123-PIMSK)

Borne 6 marqué "C" - c'est le rendement normalmente abierto del relais d'ALARME (ce contact est fonctionnel sur LC-103-PIMSK et LC-123-PIMSK)

Borne 7 marqué "NO" - c'est le rendement normalmente abierto del relais d'ALARME (ce contact est fonctionnel sur LC-123-PIMSK seulement)

Borne 8 - Signalée par "-" (GND) Reliez-la à la sortie de tensión negativa o a la tierra del central de control.

Borne 9 - Signalée par "+" (+12V) A reliar a una salida de tensión positiva de 9.6 -16 Vcc.

INSTALACIÓN DEL DETECTOR

Conexiones del bloque de terminales (véase la Fig. 4)

Terminales 1 y 2 - Marcados como "T1, T2" (TAMPER) Conecte estos terminales a una zona protectora normalmente cerrada de 24 horas en la unidad de control. Si se abre la tapa frontal del detector, se enviará inmediatamente una señal de alarma a la unidad de control.

Terminales 3 y 4 - Marcados como "AM: NC, C" Se trata del relé de salida del detector de la detección antimasking.

Terminal 5 marcado con "NC" - Este es NC (Normalmente Cerrado) salida de relé de ALARMA (Este contacto es funcional en el LC-103-PIMSK y LC-123-PIMSK)

Terminal 6 marcado con "C" - Este es el COMMON de los relés de ALARMA (Este contacto es funcional en el LC-103-PIMSK y LC-123-PIMSK)

Terminal 9 - Marcado como "-" (GND) Conecte a la salida de tensión negativa o a la tierra del panel de control.

Terminal 9 - Marcado como "+" (+12V) Conectelo a una salida de tensión positiva de entre 9.6 y 16 VCC.

CONFIGURACIÓN DEL DETECTOR

ACTIVAR / DESACTIVAR LED

Interruptor 1 de DIP-4. Utilizado para ajustar el "LED"

Position Up "ON" - VOYANT ACTIVE - Le voyant ROUGE s'allumera lorsque le détecteur est en condition d'alarme. (par défaut Position centrale)

Position vers le bas "OFF" - VOYANT DESACTIVE - Les voyants sont désactivés.

REMARQUE : Le statut de l'interrupteur "LED" n'affecte pas le fonctionnement du relais. Lorsqu'une intrusion est détectée, le relais d'alarme déclenchera une alarme pendant 2 sec. En condition d'alarme AM, les 3 voyants clignotent simultanément, peu importe la position de l'interrupteur LED.

FONCTION ANTIMASQUE


Interruptor 2 de DIP-4 para el réglae de "AM" - función antimasking

Position vers le haut "ON" - protection contre el masquerado del detector d'une distance de 0,4 m et moins. (par défaut Position centrale)

Position vers le bas "OFF" - protection contre el masquerado del detector d'une distance de 0,8 m et moins.

FUNCIÓN DE ANTI-ENMASCARAMIENTO

Interruptor 2 del microinterruptor DIP-4. Utilizado para ajustar la



For ULC installations use sensitivity settings between MIN and MID positions and PIR pulse count set to AUTO. (DIP 3 is OFF)

Fig. 3 Lens Pattern I Patrón de la lente I Portée de la lentille
Área de Coperatura I Charakterystyka detekcji





Fig. 4 Terminal block I Bloque de terminales I Plaque à bornes I
Morszettiera I Opis zacisków



Note: The "MW" and "PIR" pots may need to be adjusted to the Maximum positions in order to achieve maximum area of coverage as indicated in Fig. 3.

Fig. 5 PCB Layout				
1 PIR	Ajuste de Sensibilidad PIR	Réglage de la sensibilité du détecteur IRP	Regulazione czułości sensibilidade PIR	Regulación czuñosi podczewieni (PIR)
2 Switch for setting	Interruptor del ajuste	Interrupteur de réglage	Interruptori d'impostazione	Przelacznik funkcji
3 Tamper switch	Interruptor de seguridad	Interruptor anti-sabotaje	Deviatore Anti-sabotaggio	Przelacznik antysabotażowy
4 MW Sensitivity Adjustment	Ajuste de Sensibilidad MW	Réglage de la sensibilité de l'hyperfréquence	Regulazione Sensibilità microonda	Regulación czuñosi mikrofali

DSC erklaerer herved at denne komponenten overholder alle viktige krav samt andre bestemmelser gitt i direktiv 1999/5/EC.

Por este medio, DSC, declara que este equipamiento està en conformidad con los requisitos esenciales y otras determinaciones relevantes para la Directiva 1999/5/CE.

DSC bekræfter hærdt at denne apparat uppfyller de væsentlige krav og andre bestemmelser i Direktivet 1999/5/EC.

Con la presente, Digital Security Controls dichara que questo prodotto è conforme ai requisiti essenziali e altre disposizioni rilevanti alla Direttiva 1999/5/CE.

Hierdurch erklärt DSC, daß dieses Gerät den erforderlichen Bedingungen und Voraussetzungen der Richtlinie 1999/5/EC entspricht.

Άλλη παρόντως, η DSC, δηλώνει ότι αυτή η εποικούσα είναι σύμφωνη με τις συναπόντιες και με άλλες σχετικές αναφορές της Οδηγίας 1999/5/ΕΚ.

Hierbij verklaart DSC dat dit toestel in overeenstemming is met de eisen en bepalingen van richtlijn 1999/5/EC.

Par la présente, DSC déclare que cet article est conforme aux exigences essentielles et autres relevantes stipulations de la directive 1999/5/EC.

DSC vakuuttaa lähteenä täytävästä direktiivin 1999/5/EEC olevan mäistä vastaamukset.

Hereby, DSC, declares that this device is in compliance with the essential requirements and other relevant provisions of Directive 1999/5/EC.

The complete R & TTE Declaration of Conformity can be found at www.dsc.com/ultralite/rectif.htm.



EN50131-1 EN50131-2-4 Grade 2 Class 2
FCC ID:F5306LC3105 IC ID:160A-06LC3105



For UL/ULC installations use only detectors operating at 10.525GHz.
UL/ULC tested operation of the product at 0 ~ 49°C, 93%RH.
Use only resistive loads on the relay outputs.

Warning! Changes or modifications to this equipment not expressly approved by the party responsible for compliance (DSC Ltd.) could void the user's authority to operate the equipment. This device complies with part 15 of the FCC rules. Operations are subject to the following two conditions:

(1) This device may not cause harmful interference and (2) This device must accept any interference received, including interference that may cause undesired operation.

This Class B digital apparatus complies with Canadian ICES-003. The term 'IC' before the radio certification number only signifies that Industry Canada technical specifications were met.

Wire Length	m	200	300	400	800
Wire Diameter	mm	.5	.75	1.0	1.5
Wire Length	ft.	656	984	1312	2624
Wire Gauge	AWG	24	21	18	15

WALK TESTING

IMPORTANT NOTE: Upon installation, the unit should be thoroughly tested to verify proper operation. The end user should be instructed on how to perform a walk test weekly.

Make sure detector has been set up: Pulse=1, LED=ON and protected area cleared of all people. Create motion in the entire area where coverage is desired, observe the Green LED for PIR detection, and Yellow LED for MW detection. Should the coverage be incomplete, readjust Range or relocate the detector.

Once coverage is as required, the alarm LED may be disabled. Use the optional LC-1ST wall mount / ceiling mount brackets to solve placement problems.

The brackets allow for horizontal positioning of the detector. Note: For UL installations the detector shall be tested annually.

TECHNICAL SPECIFICATION

Detection Method	Quad (Four element) PIR & microwave pulse Doppler
Power Input	9.6 to 16Vdc
Current Draw	Active: 25mA Standby: 20mA
Temp Compensation	Yes
Alarm Period	2 ± 1 sec
Alarm Outputs	LC-103-PIMSK - Form A - NC LC-123-PIMSK - Form C - NC&NO 28Vdc 0.1 A with 10 Ohm series protection resistors
AM Outputs	N.C 28Vdc 0.1 A with 10 Ohm series protection resistors open when cover is removed
TCompensación de temperatura	Activo: 25 mA En reposo: 20 mA
Tamper Switch	N.C 28Vdc 0.1 A with 10 Ohm series protection resistors open when cover is removed
Warm up Period	1min
LED Indicator	LED's are blinking during warm up period and self testing
Red LED	ON during alarm
Green LED	PIR CHANNEL
Yellow LED	MW CHANNEL
RF Immunity	10 V/m plus 80% AM from 80 MHz to 2GHz
Static Immunity	8kV contact, 15kV air
Transient Immunity	2.4kV @ 1.2joules
Operation Temp	-10°C ~ +55 °C (14 °F-131 °F)
Dimensions	118mm x 62.5mm x 41mm (4.65" x 2.46" x 1.61")
Weight	102gr. (3.6oz.)

NOTE: This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to Part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures: -- Reorient or relocate the receiving antenna.

-- Increase the separation between the equipment and receiver.

-- Connect the equipment into an outlet on a circuit different from that to which the receiver is connected. -- Consult the dealer or an experienced radio/TV technician for help.

Utilice solo cargas resitivas en las salidas de los relés

posiciones máximas para conseguir la máxima superficie de cobertura, tal y como se indica en la fig. 3.

REQUISITOS DE TAMAÑO DE LOS CABLES

Utilice cables de calibre 22 AWG (0,5 mm) o de mayor diámetro. Utilice la siguiente tabla para determinar el calibre (diámetro) del cable y su longitud entre el detector y el panel de control.

Lunghessa	m	200	300	400	800
Diametro	mm	.5	.75	1.0	1.5
Lunghessa	ft.	656	984	1312	2624
Calibre	AWG	24	21	18	15

TEST DE FONCTIONNEMENT

REMARQUE IMPORTANTE : Lors de l'installation, l'unité doit être minutieusement testée pour s'assurer de son bon fonctionnement. L'utilisateur final doit savoir comment réaliser un test de fonctionnement hebdomadaire. Assurez-vous que le détecteur a été configuré de la façon suivante : Impulsion=1, Voyant=allumé et zone protégée évacuée. Créez un mouvement dans toute la zone à couvrir, observez le voyant vert pour la détection PIR, et le voyant jaune pour la détection hyperfréquence. Si la couverture est incomplète, ajustez la portée ou déplacez le détecteur.

Une fois la couverture appropriée est atteinte, le voyant d'alarme peut être désactivé.

Assuriez-vous que le détecteur soit installé au plafond / mural LC-1ST en option pour résoudre les problèmes de placement. Les supports permettent de placer le détecteur horizontalement.

Utilisez les supports de montage au plafond / mural LC-1ST en option pour résoudre les problèmes de placement. Les supports permettent de placer le détecteur horizontalement.

PRUEBA DE DESPLAZAMIENTO

NOTA IMPORTANTE: Tras realizar la instalación, la unidad deberá ser probada exhaustivamente para verificar que funciona correctamente. Deberá instruirse al usuario final en el modo de realizar una prueba semanal de desplazamiento.

Los brackets permiten la colocación horizontal del detector.

Use los soportes opcionales LC-1ST para montaje en pared / techo para resolver los problemas de ubicación. Estos soportes permiten colocar el detector en posición horizontal.

CARACTERISTICAS TÉCNICAS

Método de detección	Impulsión hyperfréquence à effet Doppler et PIR Quad (cuatro elementos)
Alimentación en entré	9.6 a 16 Vcc
Appel de courant	Actif: 25 mA En En veille: 20 mA
Compensation de temp.	OUI
Durée d'alarme	2 ± 1 sec
Sortie d'alarme	LC-103-PIMSK Format A NC LC-123-PIMSK Format C NC&NO 28Vdc 0.1 A con 10 Ohm resistencias de protección en serie
Salidas de la alarma	N.F 28 Vcc 0.1 A avec une résistance de protection en série de 10 Ohm - s'ouvre lorsque le couvercle est retiré
Interruruptor anti-sabotage	N.F 28 Vcc 0.1 A avec une résistance de protection en série de 10 Ohm - s'ouvre lorsque le couvercle est retiré
Durée de préchauffage	1 min
Voyant rouge	Allumé pendant une alarme
Voyant vert	CANAL IRP
Interruuptor de seguridad	N.C 28 VCC, 0.1 A con resistencia protectora en serie de 10 ohm; se activa cuando se retira la tapa
Periodo de calentamiento	1 min
Indicador LED	Los LED parpadean durante el periodo de calentamiento y la prueba automática
LED rojo	Encendido durante la alarma
LED verde	CANAL DEL SENSOR PIR
LED amarillo	CANAL DE MICROONDAS
Inmunidad a radiofrecuencia	10 V/m más 80% AM de 80 MHz a 2GHz
Inmunidad a electricidad estática	8kV en contacto, 15kV en el aire
Inmunidad transitoria	2.4 kV a 1.2 joules
Temperatura de funcionamiento	-10°C ~ +55°C (14°F ~ 131°F)
Dimensiones	118mm x 62.5mm x 41mm (4.65" x 2.46" x 1.61")
Peso	102gr. (3.6oz.)

N'utilisez que des charges résistives sur les sorties de relais

Cet appareil numrique de la classe B est conforme à la norme NMB-003 du Canada.

Utilice solo cargas resitivas en las salidas de los relés

Longueur du fil	m	200	300	400	800
Diamètre du fil	mm	.5	.75	1.0	1.5
Longueur du fil	ft.	656	984	1312	2624
Calibre du fil	AWG	24	21	18	15

SPECIFICHE DEI CONDUTTORI

Usare un conduttore AWG n. 22 (0,5 mm) o di diametro maggiore. Usare la tabella seguente per determinare il diametro del conduttore in base alla lunghezza del collegamento tra il rilevatore e la centrale.

Lunghezza Conduttore	m	200	300